

FIRE ALARM NOTICE

TO: ALL COMMERCIAL CONTRACTORS

The Creve Coeur Fire Protection District **requires** a separate permit for fire alarm systems.

Even if your approved ***architectural*** drawings show placement of fire alarm devices, you are still required to submit (2) two sets of fire alarm drawings for the required, separate, fire district fire alarm permit. If the architectural drawings for the same project are signed and sealed and include proper NFPA-72 compliant fire alarm device placement, the separate fire alarm submittal will not be required to be signed and sealed. If this is not clear, please contact the Fire Marshal's office for clarification of this requirement.

If you have a small project that requires any combination of (2) two or less new or relocated fire alarm devices such as smoke detectors, horn/strobes, etc., the Fire District will not require a fire alarm permit.

If you are not sure if a separate fire alarm permit is required on your project, please contact the Fire Marshal's office at 314-432-5570.

It is the general contractor's responsibility to make sure a fire alarm permit has been secured and approved fire alarm drawings are on the job site for final approval.

